

# Town of Holly Springs




## 2015 ETJ Extension Request

### Legend

- Proposed Water Tank
- Existing Water Tank
- CIP Water Lines
- Duke Progress Energy Land
- ETJ\_Expansion\_Request\_2015
- SRUSA Expansion Request 2015
- Town Jurisdiction 15.53 Sq Miles / 10,278 Acres
- Extraterritorial Jurisdiction (ETJ) 5.78 Sq Miles / 3,697 Acres
- Short Range Urban Service Area (SRUSA)
- Apex Town Limits Updated April 2015
- Apex ETJ
- Cary Town Limits Updated April 2015
- Cary ETJ
- Fuquay Varina Town Limits Updated April 2015
- Fuquay Varina ETJ
- Holly Springs/Cary Annexation Agreement 2003
- Apex/Cary Service Area Agreement
- Holly Springs/Apex Annexation Agreement 2013 (pending)
- Holly Springs/Fuquay-Varina Annexation Agreement 2013

### Corporate Town Limits by Year



The Town expressly denies any and all responsibility for errors, if any, in the information/data or for the misuse of the information/data by the user or anyone else. The user understands that he or she should verify the accuracy of the information/data.

Map Prepared By  
Department of Planning & Zoning  
Town of Holly Springs  
PO Box 8 / 128 S. Main Street  
Holly Springs, NC 27540  
(919) 557-3908

Visit Us on the Web

[www.hollyspringsnc.us](http://www.hollyspringsnc.us)

Date: May 2015



PROPOSED 1 MG ELEVATED  
STORAGE TANK  
DESIGN 2010  
CONSTRUCTION 2011  
(LOCATION DEPENDS  
UPON DEVELOPMENT)

EXISTING 1.0 MG ELEVATED  
STORAGE TANK

EXISTING 1.0 MG ELEVATED  
STORAGE TANK

EXISTING 0.5 MG ELEVATED  
STORAGE TANK

### NOTES:

1. WATERLINES SHOWN ARE PROPOSED 12" AND 16" EXTENSIONS (MINIMUM).
2. IN ADDITION TO WATERLINES SHOWN, NEW MAJOR ROADWAYS WILL REQUIRE 12" OR 16" WATERLINE EXTENSIONS.
3. NEW DEVELOPMENT IS REQUIRED TO INSTALL 12" OR 16" WATERLINES AS NECESSARY TO MEET ENGINEERING DESIGN AND CONSTRUCTION STANDARDS.